

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1288:113 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Gamewell, 60 Pleasant Street, Ashland, MA 01721
Contact: *Ray Wood (508) 231-1400 Fax (508) 231-0900

DESIGN: Model FLEXALARM EE300/3000. Power-limited; local, local with shunt, auxiliary, remote station (protected premises) or proprietary (protected premises) service; coded or non-coded; automatic or manual; waterflow and releasing device service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

EE-300/30320-100	MB-30325	MB-30319-10
MB4-30427	LR-30326-1	MT 30527
D2P 30437	Z2V-30754	TP-30759
LE-30709-01	LR-30326-1	PF-30329
DIB-30327-12	30242	D3-30343-10
AHR-30328	PXU/PSE-30317	K8P-30431
CM-30350-10	CX-30351	Z3A-30429
Z4B-30428	30405/30405-01	X-29946
Y-29946-1	ELT-3038	XABS-30137
PNIS-30240	PNIS-30239	67888/67921
30480-01	R-30414-R	K4SP

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a control unit for use with separately listed compatible initiating and indicating devices. Preprogrammed time delay function is approved for automatic extinguishing system release operation only.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 06-11-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 11, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager